



Proj Coord: **Adam Dillon**
 PC Cell: **720-695-4878**
 Designed By: **Adam Dillon**
 Designer Cell: **720-695-4878**
 Design Comp Date: **3/10/2021**

Revised By:
 Date:
 ROW Agent:

Const. Coord: **Shane Powell**
 CC Cell: **3036371282**

Sub/Circuit/Phase: **14-5 B**
 Right of Way (All):
 Spec. Equipment:
 Primary/CT Metering:
 Locates Req'd:

Work Order: **202103029**
 Service Order: **2021011214**
 Project Name: **STEVE JORDAN_7 ROOSEVELT RIDGE_RES.200-AM**
 Description: **CONSTRUCTION SERVICE ORDER**

Equipment Loc: **6418**
 Service Loc: **6418**
 Contact Ph: **720-261-7212**

Svc Address: **7 ROOSEVELT RIDGE RD**
 City: **BLACK HAWK**
 County: **GILPIN**
 Sec/Twn/Rng: **18 2S 72W**



Conductor Summary

Conductor Size	Status	Placement	Type	# Wires	Span (Ft)	Total
UP 1/0 EPR C	New	UG	PRIMARY	1	343	363
UP 4/0 TXUSE C	New	UG	SECONDARY	1	102	122

Bore/Trench Summary

COMMENTS

Inspection By: _____ Date: _____ Construction By: _____ Date: _____

Reviewed/Approved By: _____ Date: _____

Disclaimer: The design and map print is not survey grade, nor set to a specific scale.

Source: Esri, DigitalGlobe, GeoEye, Earthstar Geographics, CNES/Airbus DS, USDA, USGS, AeroGRID, IGN, and the GIS User Community



Coordinator:	Adam Dillon	Work Order:	202103029
Cell:	7206954878	Service Order:	2021011214
Designer:	Adam Dillon	Project Name:	STEVE JORDAN_7 ROOSEVENT RIDGE
Cell:	7206954878	Description:	CONSTRUCTION SERVICE ORDER
Design Date:	3/10/2021 8:52:51AM	Customer:	STEVE JORDAN

Location	Assembly	Quantity	Status	Comments
1	TRANSFORMERBANK	1	Existing	
	UP 1/0 EPR	1,126	Existing	
	UP UM6-1-10	1	Install	
2	M UR7-BH-48	343	Install	
	UP 1/0 EPR C	363	Install	
	UP UG7-15	1	Install	
	UP UM1-7NC-1	1	Install	
	UP UM50-POLY2	360	Install	
	UP UM6-1-10	1	Install	
	UP UM6-34	1	Install	
3	CONS-UG	1	Install	
	UP 4/0 TXUSE C	122	Install	
	UP UM50-POLY2	110	Install	



Coordinator: **Adam Dillon**
 Cell: **7206954878**
 Designer: **Adam Dillon**
 Cell: **7206954878**
 Design Comp Date: **3/10/2021**

Work Order: **202103029**
 Service Order: **2021011214**
 Project Name: **STEVE JORDAN_7 ROOSEVENT RIDGE**
 Description: **CONSTRUCTION SERVICE ORDER**
 Customer: **STEVE JORDAN**

STATISTICAL SUMMARY

		PRIM	SECD	SERV	TRAN	CONS	SL	MET	TRA	POLES
INSTALL	OH:	-	-	-	-	-	-	-	1	-
INSTALL	UG:	343	102	-	-	1				
RETIRE	OH:	-	-	-	-	-	-	-	-	-
RETIRE	UG:	-	-	-	-	-				

ASSEMBLY SUMMARY

ASSEMBLY	DESCRIPTION	INSTALL	USED	RETURNED	RETIRE	SALVAGED
M UR7-BH-48	TRENCH, BACKHOE, 48"	343			-	
UP 1/0 EPR C	CABLE, DIST PRI UG, 1/0 EPR, IN CONDUIT	363			-	
UP 4/0 TXUSE C	CABLE, DIST SEC UG, 4/0 TXUSE, IN CONDUIT	122			-	
UP UG7-15	TRANSF, 1-P PDMT, 120/240V, 15 KVA, PV	1			-	
UP UM1-7NC-1	SLEEVE, FBG, 1PH XFMR, 37X43X32	1			-	
UP UM50-POLY2	CONDUIT, POLY, 2	470			-	
UP UM6-1-10	ELBOW, LOAD BREAK, 1/0 EPR	2			-	
UP UM6-34	ARRESTER, DEAD BRK SURGE ELBOW	1			-	

MATERIAL ITEM SUMMARY

DESCRIPTION	MAT ITEM ID	INSTALL	USED	RETURNED	RETIRE	SALVAGED
POLY 2" SDR 13.5	13001699	470			-	
ELBOW 1/0 UG ARRESTOR	1591094	1			-	
EQUIP TANK GRND #2 STR	17210500N	1			-	
CLAMP 5/8" GRND ROD CWC	17311000N	1			-	
TRANSF Bk 6-POS 350-5/8"	18041642	3			-	
CLEAT PADMT TRANS 2X6X1/4	31005999N	2			-	
SLV FIB TRANSF 37X43X32(1PH)	43501007	1			-	
GRND ROD CWC 5/8"X10"	53828510	1			-	
TERM ELBOW 1/0 AL .220	66936542	2			-	
LOAD TRACKER LM FCI (PDP)	70050001	1			-	



Coordinator:	Adam Dillon	Work Order:	202103029
Cell:	7206954878	Service Order:	2021011214
Designer:	Adam Dillon	Project Name:	STEVE JORDAN_7 ROOSEVENT RIDGE
Cell:	7206954878	Description:	CONSTRUCTION SERVICE ORDER
Design Comp Date:	3/10/2021	Customer:	STEVE JORDAN

DESCRIPTION	MAT ITEM ID	INSTALL	USED	RETURNED	RETIRE	SALVAGED
GRND WIRE BARE 4 SOL CU SD	72500401N	1			-	
CABLE 1/0 EPR 15KV JKTD 220MI	9129260	363			-	
CABLE SEC 4/0 TX USE	9723307	122			-	
15KVPM,120/240,72/762,1-PH	99851813	1			-	
NON-STOCK FOR INTERFACE ONLY	INTERFACE	-			-	